

Plain Language Summary for New Source Review (NSR) Renewal Application for Air New Source Review Permit Number 5409

The following summary is provided for this pending air permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

El Paso Electric Company (CN600352819) has submitted an application for renewal of permit number 5409. The Copper Generating Station (RN100215490) generates electricity at 651 Hawkins Blvd, El Paso, El Paso County.

This renewal will authorize the continued operation of equipment used to generate electricity at the Copper Generating Station, including a combustion turbine, oil storage tank, and fugitive emissions. El Paso Electric Company has certified there will be no changes to the permit. The following permitted emission rates will remain the same.

Pollutant	Total Proposed Emissions (tons per year)
VOC	50.25
NO _x	407.51
CO	330.01
PM	<0.01
PM ₁₀	85.41
PM _{2.5}	<0.01
SO ₂	98.30

The combustion turbine will continue to utilize water injection to reduce NO_x emissions. El Paso Electric Company will continue to implement good operating practices.